

Notes:

1. Customer facilities shall comply with Company Standards, the National Electrical Code, and authorities having jurisdiction. All material shall be suitable for outdoor use. Equipment to be installed at a location designated by the Company.
2. This installation applies to two (2) or more meters at one location.
3. Customer shall furnish and install a Company approved, lockable, non-fused disconnect switch on the supply side of the meter. The Company shall control the supply side disconnect and it shall be available 24 hours a day without notice.
4. For identification purposes, all meter sockets and utility disconnects will be plainly and permanently labeled to designate the particular apartment or office served. Each meter should have a separate cover that can be removed for repairs without disturbing other meters. See label 9-5.
5. This installation applies to two (2) or more meters at one location.
6. This installation can be adapted for underground (see D9-5) or overhead (D9-4) service.
7. A main disconnect is required for seven or more disconnects - (NEC). A main disconnect is recommended in all cases for isolation of this disconnect/meter group from any other groups served by the same transformer. Utility connection shall be made on the line side of main disconnect or junction box.
8. When installed as an underground service, the Customer shall install 80 lb non-metallic (manila or grass) pull line or bull tape in the conduit.
9. If a current transformer (CT) installation is required, see drawings D9-6 and D9-7.
10. See section 8.5 for junction box sizing and Customer supplied connectors.

911 address shall be a minimum 3" lettering marked on meter enclosure, pole, or durable material attached to pole and should be visible from street. (See section 3.4)

CALL 811 TWO BUSINESS DAYS BEFORE YOU DIG


In locations with underground facilities, the Customer shall notify One Call and shall have One Call locate all underground facilities before digging. It shall be the responsibility of the Customer to stay clear of all underground facilities.

ENTERGY SERVICES, INC.	
CUSTOMER OWNED MULTIPLE METER	
3Ø 277WYE/480DELTA VOLT	
SELF CONTAINED METER ARRANGEMENT	
APPROVED BY: JRH	DATE: 01/15/2013
CHECKED BY: JED	SCALE: NONE
DRAWN BY: krich95	
No. D9-12	
PLOT 1=1 SH. 1 OF 1	

1	01/13	REVISION FOR DRAWING SS11.6-5	JED	
NO.	DATE:	REVISION	BY:	APPR:



UNDERGROUND



NOTES:

1. See section 8.6 for junction box sizing and Customer supplied connectors.
2. All 480 volt applications required to be available for Company personnel 24 hours a day without notice.
3. Consult the Company.

ENTERGY SERVICES, INC.

**TYPICAL UNDERGROUND 3Ø 4 WIRE
277/480 INSTALLATIONS**


APPROVED BY: JRH	DATE: 01/14/2013
CHECKED BY: JED	SCALE: NONE
DRAWN BY: krich95	CEA NO.

1	01/13	REVISION OF DRAWING SS11.8-5	JED	
NO.	DATE:	REVISION	BY:	APPR:



No. D9-5	
PLOT 1=1	SH. 1 OF 1

OVERHEAD



Caution:

For 480 volt service, see drawing D9-2.

For 277/480 volt service, Customer shall furnish and install a Company approved, Company lockable, non fused disconnect switch on the supply side of the meter base and a separate load side disconnect with overcurrent protection within 2 ft. of the meter.

Company shall control the supply side disconnect. It shall be labeled "Utility Disconnect" see §1.5 Labels and Disconnects and it shall be available to Company 24 hours a day without notice.

NOTES:

1. Consult the Company.

ENTERGY SERVICES, INC.

TYPICAL OVERHEAD 3Ø 4 WIRE 277/480 INSTALLATION

APPROVED BY: JRH	DATE: 01/14/2013
CHECKED BY: JED	SCALE: NONE
DRAWN BY: krich95	CEA NO.

No. D9-4



PLOT 1=1 SH. 1 OF 1

1	01/13	REVISION OF DRAWING SS11.8-5	JED	
NO.	DATE:	REVISION	BY:	APPR:




TABLE 9.1.3: GUIDELINE FOR METER TRANSFORMER ENCLOSURE WITH MULTIPLE CIRCUITS

Total Customer Conduits (4" min)	Maximum Conductor Size	Minimum Dimensions		
		Depth	Width	Height
Up to 4	600 kcmil	14"	32"	40"
5-6	500 kcmil	14"	32"	54"

CTs will be placed at center. Customer Conduit spaced evenly.
Service connections shall not be made in an instrument transformer enclosure.
For larger sizes, consult the Company.

CALL 811 TWO BUSINESS DAYS BEFORE YOU DIG

In locations with underground facilities, the Customer shall notify One Call and shall have One Call locate all underground facilities before digging. It shall be the responsibility of the Customer to stay clear of all underground facilities.

ENTERGY SERVICES, INC.

CURRENT INSTRUMENT TRANSFORMER FOR OVERHEAD SERVICE

APPROVED BY: JRH DATE: 11/15/2012
CHECKED BY: JED SCALE: NONE
DRAWN BY: krich95 CEA NO.

No. D9-6




PLOT 1=1 SH. 1 OF 1

1	10/12	REVISION OF DRAWING SS11.8-3	JED	
NO.	DATE:	REVISION	BY:	APPR:

911 address shall be a minimum 3" lettering marked on meter enclosure, pole, or durable material attached to pole and should be visible from street. (See section 3.4)

CALL 811 TWO BUSINESS DAYS BEFORE YOU DIG

In locations with underground facilities, the Customer shall notify One Call and shall have One Call locate all underground facilities before digging. It shall be the responsibility of the Customer to stay clear of all underground facilities.



MAIN MAY BE DIRECTLY ABOVE OR ON EITHER SIDE OF CT ENCLOSURE

Main Disconnect: Readily accessible to Company at all hours with no notice


NOTES

1. All material, except instrument transformers, meter, and meter enclosure are to be furnished, installed, and maintained by the Customer in a location approved by the Company.
2. Instrument transformers and meter enclosure are to be furnished by Company and installed by the Customer.
3. Company reserves the right not to connect service if Company representative considers the installation not safe or not adequate.
4. Service structure shall be as close as possible to the Company pole to which the service is to be connected, not to exceed 150 ft.
5. Use masonry anchors to secure the meter arrangement (plastic anchors are not allowed).
6. Conductor shall be installed in conduit where exposed.
7. PTs, when required, are mounted on the side of CT enclosure closest to meter.
8. Single phase 120v/240v 3 wire service requires only 2 CTs.
9. More than two conductors may require larger size enclosures. Consult the Company.
10. When the Customer provides, owns, installs, and maintains the cable to the Company's transformer, a junction box is not required. Consult the Company. See section 8.5 for junction box sizing and Customer supplied connectors.
11. All Meter Transformer enclosures shall: Have a metal or 3/4" treated plywood back-plate in addition to the back wall of the enclosure, be UL listed, be weather proof/rain-tight (NEMA 3 r), be lockable, be side hinged and be minimum Aluminum or 14 gauge G90 steel enclosure.

TABLE 9.1.3: GUIDELINE FOR METER TRANSFORMER ENCLOSURE WITH MULTIPLE CIRCUITS

Total Customer Conduits (4" min)	Maximum Conductor Size	Minimum Dimensions		
		Depth	Width	Height
Up to 4	600 kcmil	14"	32"	40"
5-6	500 kcmil	14"	32"	54"

CTs will be placed at center. Customer Conduit spaced evenly. Service connections shall not be made in an instrument transformer enclosure. For larger sizes, consult the Company.



ENTERGY SERVICES, INC.	
CURRENT INSTRUMENT TRANSFORMER FOR UNDERGROUND SERVICE	
APPROVED BY: JRH	DATE: 01/15/2013
CHECKED BY: JED	SCALE: NONE
DRAWN BY: krich95	CEA NO.
No. D9-7	
PLOT 1=1 SH. 1 OF 1	

1	01/13	REVISION OF DRAWING SS11.8-4	JED	
NO.	DATE:	REVISION	BY:	APPR:



Label: When permanently attached tags or labels are required, they shall be red background with white letters and UV resistant. The lettering on each label/tag shall be 3/16 inch or larger and be either raised or incised on each tag. Each tag shall be riveted or glued to the meter loop or switch.

- For Net Metering, interconnection customer shall label meter.
- For Multiple Service drops to the same building more than 10 feet apart, Customer shall label each service drop's meter-socket with an arrow pointing to other service drop meter(s) and a description of the location (Examples: Service #1 Suite 10 located at northeast corner of building, Service #2 Suite 20 located at southwest corner of building)
- For multiple meters, the meter enclosures and disconnects shall be labeled with suite or apartment identification.
- For 480 volt services the disconnect ahead of the meter shall be labeled utility disconnect
- In areas where cable can be owned by Company or Customer, for Customer owned cable, Customer supplied label shall say "Customer owned cable" (two required). One label shall be installed by Customer on meter socket; one label shall be given to Company for installation on the transformer.

Consult the Company.

Disconnect or Disconnect switch shall

- Be lockable (by the Company)
- Be available to Company personnel at all hours without notice
- Be within sight of service entrance meter preferably adjacent to meter, but within 10 feet of meter,
- Have an open and visible break verifiable by Company personnel
- Be load break and one piece
- Have a label (see definition of label)
- In underground service normally is on the customer side of a junction box

The Company may operate and lock down this switch for safety, non-payment or any other valid reason. Review the applicable drawings for proper installation. Disconnect switch box design and location must be approved by the Company in advance of installation.

8.5 Junction Box Requirements

A junction box is equipment designated/approved by the Company where the Customer's service terminals are joined to the Company's cables.

Junction boxes are not normally required or accepted for 120/208/240volt self-contained single meter installations or residential services unless a main disconnect is required ahead of the meter.

When the Customer provides, owns, installs & maintains the secondary wire to the Company's transformer, a Junction box is not required. Consult the Company for the requirements in your area.

A Customer Supplied Company approved Junction box is required when Company owned Underground conductors feed the Underground Service and:

- A main disconnect is required (e.g. 480 volt service, etc.);
- multiple services are joined together; or
- transformer rated services exist;

Consult the Company.

The Customer supplied junction box shall:

- Have a rain-tight (NEMA 3R) weather proof front cover that is hinged to the side(s)
- Have a locking mechanism to secure it suitable for a Company padlock
- Be UL listed or a UL listed Company approved alternative

Junction boxes used for various situations are shown in Drawings D9-7, D9-9, and D9-10.

The customer shall supply UL listed connectors inside, which will be the point of common coupling between Company and Customer. These connectors shall be sized no less than 125% of continuous load, plus 100% of the non-continuous load. Connectors shall be suitable for both copper and aluminum. Insulated multi connector block or buss bar type shall be used. Buss bar or bare multi connector block(s) type shall be fastened properly to the back of junction box. Insulated multi connector block(s) shall not be fastened.

A durable marking for color or word coding shall be installed. The neutral conductor shall have a white marking or a suitable identifying mark. The next section of the terminals shall have color suitable for applicable voltage. Plastic anchors are not allowed.

The customer supplied connector should be located in the center of the junction box four feet from grade or lower (normally should be low enough that the lineman can work on without a ladder).

Without prior Company approval, a junction box may only serve one meter, one main, or one weatherproof wire way.

Table 8.5: Guideline for Junction Box Use with Multiple Circuits

Total Customer Conduits (4" min)	Maximum Customer Conductor Size	Minimum Dimensions		
		Depth	Width	Height
1	600 kcmil	12"	24"	24"
2-4	600 kcmil	12"	36"	36"
5-6	500 kcmil	12"	48"	48"

Company conductors shall enter from the bottom

For larger sizes consult the Company.