

4.7 Services for Mobile Home Parks

Mobil Home Parks are five or more mobile homes or trailers and accessory buildings on a continuous parcel of land used by its occupants or owners. These parks shall be served at a common point as shown in drawings SS4.7-1, SS4.7-2 and SS4.7-3. The park management shall be responsible for running service from the disconnect beyond the 120/240 volt Entergy meter to the individual trailers. On overhead service from Entergy, Entergy shall have exclusive use of the pole where the point of common connection is. Entergy recommends the Park use underground feeders to individual trailers to avoid the hazards of tall trailers contacting electric lines. If the Park wishes to distribute the electricity overhead it must use a separate pole from the Entergy feed pole. Consult the NEC for overhead clearances and underground construction on Customer owned lines.